From:	Deborah Perry
To:	Joshua Hill; Terry Lamb Sr.
Cc:	Danny Mapili - WPD-C (danny.mapili@gsa.gov); Mark Radlinski; Jeremy Parmer; mark.stadsklev@gsa.gov; marcus.witowski@gsa.gov; Tracey D. Dickens; Steve Braesch; Lewis Cabbagestalk
Subject:	FERC Genesis Stairwell Work
Date:	Monday, November 28, 2016 2:32:11 PM

Josh –

I'm following up on Steve's e-mail of November 14th regarding the stairwell card readers. We did submit the information provided to us by Genesis to a third-party consultant, and came up with some additional questions which will need to be addressed.

- *Will the current system sequence of operation for the fire alarm system remain the same as it relates to egress doors?*
- *Are modifications to the fire alarm system required? If so, what are they? Can the current fire alarm panel support the additional equipment?*
- *Does any of the Genesis work involve tying into the base building emergency generator? If so, it has not been determined if the system has adequate spare capacity to support the additional load for the proposed equipment. Additionally, the Landlord has not approved any tie in to the generator.*
- *Who, if anyone, has done a code compliance review and have permits been issued?*
- *There are several components to this job that directly affect the base building systems where Landlord's contractor must be used, i.e. Lock Technology, Red Hawk.*

In order to move forward with this work, it is felt that a meeting with appropriate representatives from FERC, Genesis and the Landlord should take place so all the issues/questions can be addressed and clarified amongst the parties. Can you provide a date/time when FERC and Genesis may be available? Thank you.

Deborah

Deborah A. Perry, CPM
Asset Manager
Union Center Plaza Management Corp.
5301 Wisconsin Avenue, N.W., Suite 510
Washington, D.C. 20015
202-789-0754 (direct)
202-289-6000 (main)
202-898-0053 (fax)
202-215-9616 (cell)
E-mail: dperry@ucpmanagement.com

The information contained in this message may be privileged and confidential and protected from disclosure. If the reader of this

message is not the intended recipient, or an employee or agent responsible for delivering this message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by replying to the message and deleting it from your computer. Additionally, this e-mail is not intended to legally bind the sender and shall not constitute a binding proposal or offer unless specifically stated that the sender intends this e-mail to be legally binding.